



May 29, 2014

ADDENDUM NO. 1

**CIVIC FACILITIES AIR CONDITIONING REPLACEMENT PROJECT
CIP NO. 14-03**

The plans and specifications prepared by the Engineering Department for the City of National City entitled, "CIVIC FACILITIES AIR CONDITIONING REPLACEMENT PROJECT", are hereby amended as follows:

- 1. DESCRIPTION OF WORK. Replace two (2) 7.5-ton rooftop heat pump units with economizers at the Martin Luther King Jr Community Center: ADD: "16. Provide and install smoke detectors for each unit and connect to the facility fire alarm system. Coordinate and ensure the functionality of the smoke detectors with the existing system."**

ALL BIDDERS SHALL ACKNOWLEDGE RECEIPT AND ACCEPTANCE OF THIS ADDENDUM NO. 1 BY SIGNING IN THE SPACE PROVIDED BELOW AND RETURNING VIA EMAIL TO JHERNANDEZ@NATIONALCITYCA.GOV OR BY FAX TO (619) 336-4397.

This Addendum No. 1 must be acknowledged on Appendix 1-1 of the Bidder's Proposal and SUBMITTED WITH YOUR BID.

BY ORDER OF THE CITY ENGINEER OF THE CITY OF NATIONAL CITY.

05/29/2014

Date

**Stephen Manganiello
City Engineer**

RECEIPT ACKNOWLEDGE BY:

DATE: _____

Signature

Print name

Company



CLARIFICATIONS

CIVIC FACILITIES AIR CONDITIONING REPLACEMENT PROJECT CIP NO. 14-03

1. Q: In coating of AC carrier units the coating is for the condenser only or does it include the evaporator?
A: The specifications are correct. Only the condenser shall be coated.

2. Q: With regards to the R22 Condenser: You already have a cost estimated for that condenser unit replacement. Do you have the specs and or supplier information for the condenser that you used for the estimate of the replacement?
A: All information that is available to the owner has been provided to bidders.

Date: 05/29/2014

Steve Manganelli
City Engineer